

STATE OF IOWA  
DEPARTMENT OF COMMERCE  
UTILITIES BOARD

IN RE:  ENVIROGAS LP	DOCKET NO. P-861
----------------------------	------------------

**ORDER REGARDING CORRECTED EXHIBIT C**

(Issued October 26, 2005)

At the hearing in this case held on October 20, 2005, EnviroGas LP (EnviroGas) agreed to file a corrected petition Exhibit C to change the "maximum allowable operating pressure" from 102 pounds per square inch gauge (psig) to 100 psig and to correct the pipe specification from "ASTM D-2513-93" to "ASTM D-2513." "Maximum allowable operating pressure" appears in three places in petition Exhibit C, on the first, seventh, and twelfth pages of the exhibit. On October 24, 2005, EnviroGas filed a corrected petition Exhibit C. On corrected petition Exhibit C, EnviroGas changed the "maximum actual operating pressure" from 80 psig to 100 psig on the first, seventh, and twelfth pages of the exhibit and did not correct the "maximum allowable operating pressure." EnviroGas corrected the pipe specification as it agreed to do.

At the hearing, EnviroGas' witness Mr. Allen R. Paulson testified that EnviroGas intended to operate the proposed pipeline at 80 psig. The change of the "maximum actual operating pressure" value from 80 to 100 psig therefore appears to be a mistake.

Therefore, EnviroGas must file another corrected petition Exhibit C with the changes it agreed to make at the hearing. EnviroGas must correct both "maximum actual operating pressure" and "maximum allowable operating pressure," each of which is listed in three places on petition Exhibit C.

**IT IS THEREFORE ORDERED:**

EnviroGas must file another corrected petition Exhibit C with the changes made as discussed in the body of this order.

**UTILITIES BOARD**

/s/ Amy L. Christensen  
Amy L. Christensen  
Administrative Law Judge

ATTEST:

/s/ Judi K. Cooper  
Executive Secretary

Dated at Des Moines, Iowa, this 26<sup>th</sup> day of October, 2005.